

SECTION 05 30 00

STEEL DECKS

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

FM GLOBAL (FM)

FM APP GUIDE (updated on-line) Approval Guide
<http://www.approvalguide.com/>

FM DS 1-28R (1998) Data Sheet: Roof Systems

ARCHITECTURAL INSTITUTE OF JAPAN (AIJ)

JASS 6 (2015) Structural Steelwork Specification
for Building Construction

JAPANESE STANDARDS ASSOCIATION (JSA)

JIS B 1198 (2011) Headed Studs

JIS G 3106 (2020) Rolled Steels for Welded Structure

JIS G 3352 (2014) Deck Plate

JIS H 8641 (2021) Hot Dip Galvanized Coatings

JIS K 5552 (2010) Zinc Rich Primer

JIS K 5553 (2006) Thick Film Zinc Rich Paint

JIS Z 3801 (2018) Standard Qualification Test and
Acceptance Requirements for Manual Welding
Technique

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2026; TIA 26-1; ERTA 26-1; TIA 26-2; TIA
26-3; TIA 26-4; TIA 26-5; TIA 26-6; TIA
26-7; ERTA 26-2; ERTA 26-3) National
Electrical Code

STEEL DECK INSTITUTE (SDI)

ANSI/SDI C (2017) Standard for Composite Steel Floor
Deck - Slabs

ANSI/SDI NC (2017) Standard for Non-Composite Steel
Floor Deck

JAPAN EDITED SPECIFICATIONS (JES)
MAY 2026 EDITION

ANSI/SDI QA/QC	(2017) Standard for Quality Control and Quality Assurance for Installation of Steel Deck
ANSI/SDI RD	(2017) Standard for Steel Roof Deck
SDI DDM04	(2015; Errata 1-3 2016; Add 1 2015; Add 2 20162006) Diaphragm Design Manual; 4th Edition
SDI DDP	(1987; R 2000) Deck Damage and Penetrations
SDI MOC3	(2016) Manual of Construction with Steel Deck (3rd Edition)

U.S. DEPARTMENT OF DEFENSE (DOD)

UFC 3-301-01	(2023; with Change 1, 2023) Structural Engineering
--------------	--

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

29 CFR 1926	Safety and Health Regulations for Construction
-------------	--

UNDERWRITERS LABORATORIES (UL)

UL 209	(2011; Reprint May 2016) UL Standard for Safety Cellular Metal Floor Raceways and Fittings
UL 580	(2006; Reprint Nov 2018) UL Standard for Safety Tests for Uplift Resistance of Roof Assemblies
UL Fire Resistance	(2014) Fire Resistance Directory

1.2 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor QC approval.][for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Fabrication Drawings; G[, [_____]]

SD-04 Samples

Metal Roof Deck Units

Cellular Metal Floor Deck Units

Acoustical Material

SD-05 Design Data

Deck Units; G[, [_____]]

SD-07 Certificates

Welder Qualifications

Welding Procedures

Fire Safety

Wind Storm Resistance

Manufacturer's Certificate

Stud Manufacture's Certification

Stud Manufacture's Test Reports

1.3 QUALITY ASSURANCE

1.3.1 Deck Units

Furnish deck units and accessory products from a manufacturer regularly engaged in manufacture of steel decking. Provide manufacturer's certificates attesting that the decking material meets the specified requirements.

1.3.2 Qualifications for Welding Work

Follow Welding Procedures of JASS 6 for sheet steel and for stud welding.

Submit qualified Welder Qualifications in accordance with JASS 6 and JIS Z 3801 for sheet steel and JASS 6 for stud welding, or under an equivalent approved qualification test. Perform tests on test pieces in positions and with clearances equivalent to those actually encountered. [Test specimens shall be made in the presence of Contracting Officer and shall be tested by an approved testing laboratory at the Contractor's expense.] If a test weld fails to meet requirements, perform an immediate retest of two test welds until each test weld passes. Failure in the immediate retest will require the welder be retested after further practice or training, performing a complete set of test welds.

Submit manufacturer's catalog data for Welding Equipment and Welding Rods and Accessories.

1.3.3 Regulatory Requirements

1.3.3.1 Fire Safety

Test roof deck as a part of a roof deck construction assembly of the type used for this project, listing as fire classified in the UL Fire Resistance, or listing as Class I construction in the FM APP GUIDE, and so labeled.

1.3.3.2 Wind Storm Resistance

Provide roof construction assembly capable of withstanding a nominal uplift pressure of [3] [5] [_____] kPa when tested in accordance with the uplift pressure test described in the FM DS 1-28R or as described in UL 580

and in general compliance with UFC 3-301-01.

1.3.4 Fabrication Drawings

Show type and location of units, location and sequence of connections, bearing on supports, methods of anchoring, attachment of accessories, adjusting plate details, cant strips, ridge and valley plates, metal closure strips, size and location of holes to be cut and reinforcement to be provided, the manufacturer's erection instructions and other pertinent details.

1.4 DELIVERY, STORAGE, AND HANDLING

Deliver deck units to the site in a dry and undamaged condition. Store and handle steel deck in a manner to protect it from corrosion, deformation, and other types of damage. Do not use decking for storage or as working platform until units have been fastened into position. Exercise care not to damage material or overload decking during construction. The maximum uniform distributed storage load must not exceed the design live load. Stack decking on platforms or pallets and cover with weathertight ventilated covering. Elevate one end during storage to provide drainage. Maintain deck finish at all times to prevent formation of rust. Repair deck finish using touch-up paint. Replace damaged material.

1.5 DESIGN REQUIREMENTS FOR ROOF DECKS

1.5.1 Properties of Sections

Properties of metal roof deck sections must comply with engineering design width as limited by the provisions of JIS G 3352.

1.5.2 Allowable Loads

Indicate total uniform dead and live load for detailing purposes.

PART 2 PRODUCTS

2.1 DECK UNITS

Submit manufacturer's design calculations, or applicable published literature for the structural properties of the proposed deck units.

Provide products with an average recycled content of steel products so postconsumer recycled content plus one half of preconsumer recycled content not less than [25] [_____] percent.

2.1.1 Roof Deck

Conform to JIS G 3352-SDP2G for deck used in conjunction with insulation and built-up roofing. Fabricate roof deck units of [[0.80] [_____] mm design thickness or thicker steel] [the steel design thickness required by the design drawings] and [shop painted] [galvanized] [painted with an epoxy coating or equivalent applied to prime-coating in accordance with manufacturer's standard] [zinc-coated in conformance with JIS G 3352-SDP2G, Z27 coating class].Furnish sample of Metal Roof Deck Units used to illustrate actual cross section dimensions and configurations.]

2.1.2 Composite Deck

[Conform to JIS G 3352-SDP2G for composite deck assembly. Fabricate deck used as the tension reinforcing in composite deck of [0.80] [_____] mm design thickness or thicker steel with integrally embossed or raised pattern ribs.] [The steel design thickness required by the design drawings. Zinc-coat in conformance with JIS G 3352-SDP2G, Z27 coating class.] [Shore composite deck until the concrete has reached [75][_____] percent of its specified strength.]

2.1.3 Cellular Metal Floor Deck Units

Provide decking as wire raceways conforming to NFPA 70. Conform to [JIS G 3352-SDP2G, SS, Grade 230 Z27]; for formed [cellular] [and] [non-cellular] decking and accessories. Provide nominal thickness of the steel sheets, before galvanizing, a minimum 1.2 millimeter for the upper element of the floor deck unit, and a minimum 1.6 millimeter for the lower element of the floor deck unit [as required by the design drawings]. [Furnish one sample of each type of Metal Floor Deck Units used to illustrate the actual cross section dimensions and configuration.]

2.1.4 Form Deck

Conform to JIS G 3352-SDP2G for deck used as formwork for concrete. Fabricate form deck of [0.80] [_____] mm design thickness or thicker steel.] [the steel design thickness required by the design drawings.] [Paint with one coat of manufacture's standard paint.] [Zinc-coat in conformance with JIS G 3352-SDP2G, Z27 coating class.]

Provide sufficient welds, forming the steel sheets into the cellular floor deck unit, to develop the full horizontal shear at the plane where the steel sheets are joined.

Cellular metal floor deck units must be fluted section cells combined [on a flat plate][with a matching fluted bottom section] having interlocking type sidelaps. Provide depth, width of unit, number of cells per unit, and width of cells as indicated.

Use panels of maximum possible lengths to minimize end laps. Fabricate deck units in lengths to span 3 or more supports with flush, telescoped, or nested 50 mm laps at ends, and interlocking, or nested side laps, unless otherwise indicated. [Factory apply a standard, phosphatized and painted, baked-on enamel finish to underside of steel decking.] [[Floor] [and] [Roof] deck system design is based on shored construction.]

2.1.5 Length of Deck Units

Provide deck units of sufficient length to span three or more spacings where possible.

[2.1.6 Shop Priming

Shop prime accessories and [underside of] deck at the factory after coating. Clean surfaces in accordance with the manufacturer's standard procedure followed by a spray, dip or roller coat of rust-inhibitive primer, oven cured.

]2.1.7 Touch-Up Paint

Maintain finish of deck units and accessories by using touch-up paint whenever necessary to prevent the formation of rust. The method and extent of surface preparation and dry film thickness shall be approved by the Contracting Officer.

Provide touch-up paint for shop-painted units [of the same type used for the shop painting] [____], and touch-up paint for zinc-coated units of [an approved galvanizing repair paint with a high-zinc content, JIS K 5552] [____]. Provide touch-up paint at all welds in steel deck with a high zinc-dust content paint conforming to JIS K 5552 or JIS K 5553 and JASS 6. Remove all weld flux residue and weld splatter by wire brushing or mechanical means.

Surfaces to receive touch-up paints containing zinc dust shall be clean, dry and free of oil, grease, preexisting paint, and corrosion by-products. Spray or brush-apply the paints containing zinc dust to the prepared area in accordance with manufacturer's instructions.

2.2 ACCESSORIES

Provide accessories of same material as deck, unless specified otherwise. Provide manufacturer's standard type accessories, as specified.

2.2.1 Adjusting Plates

Provide adjusting plates, or segments of deck units, of same thickness and configuration as deck units in locations too narrow to accommodate full size units. Provide factory cut plates of predetermined size where possible.

2.2.2 End Closures

Fabricated of sheet metal by the deck manufacturer. Provide end closures minimum 0.80 mm thick to close open ends at [exposed edges of floors,] [parapets,] [end walls,] [eaves,] [and] openings through deck.

2.2.3 Partition Closures

Provide closures for closing voids above interior walls and partitions that are perpendicular to the direction of the configurations and at open ends and sides of steel roof decking. [Provide sheet steel closures above typical partitions.] [Provide sheet steel closures above fire-resistant interior walls and partitions located on both sides of wall or partition.] [Provide glass fiber blanket insulation in the space between pairs of closures at acoustical partitions.]

2.2.4 Closure Plates for Composite Deck

Support and retain concrete at each floor level. Provide edge closures at all edges of the slab of sufficient strength and stiffness to support the wet concrete. Provide metal closures for all openings in composite steel deck 6 mm and over.

2.2.5 Sheet Metal Collar

Where deck is cut for passage of pipes, ducts, columns, etc., and deck is to remain exposed, provide a neatly cut sheet metal collar to cover edges

of deck. Do not cut deck until after installation of supplemental supports.

2.2.6 Cover Plates

Sheet metal to close panel edge and end conditions, and where panels change direction or butt. Polyethylene-coated, self-adhesive, 50 mm wide joint tape may be provided in lieu of cover plates on flat-surfaced decking butt joints.

Fabricate cover plates for abutting floor deck units from the specified structural-quality steel sheets not less than nominal 1.2 millimeter thick before galvanizing. Provide 150 millimeter wide cover plates and form to match the contour of the floor deck units.

2.2.7 Roof Sump Pans

Sump pans must be provided for roof drains and must be minimum 2 mm thick steel, [flat] [recessed] type. Shape sump pans to meet roof slope by the supplier or by a sheet metal specialist. Provide bearing flanges of sump pans to overlap steel deck a minimum of 75 mm. Shape, size, and reinforce the opening in bottom of the sump pan to receive roof drain.

2.2.8 Column Closures

Sheet metal, minimum 1.2 mm thick or metal rib lath.

2.2.9 Access Hole Covers

Sheet metal, minimum 1.2 mm thick.

2.2.10 Hanger

Provide clips or loops for [utility systems] [and] [suspended ceilings] of one or more of the following types:

- a. Lip tabs or integral tabs where noncellular decking or flat plate of cellular section is 1.2 mm thick or more, and a structural concrete fill is used over deck.
- b. Slots or holes punched in decking for installation of pigtails.
- c. Tabs driven from top side of decking and arranged so as not to pierce electrical cells.
- d. Decking manufacturer's standard as approved by the Contracting Officer.

2.2.11 Shear Connectors

Provide shear stud connectors JIS B 1198 [450MPa minimum ultimate tensile strength] [and 350MPa minimum yield strength]. Submit stud manufacture's certification that the studs delivered conform to the material requirements. Submit stud manufacture's test reports for the last completed in-plant quality control mechanical tests.

2.2.12 Cant Strips for Roof Decks

Fabricate cant strips from the specified commercial-quality steel sheets not less than nominal 1.0 millimeter thick before galvanizing. Bend strips

to form a 45-degree cant not less than 125 millimeter wide, with top and bottom flanges a minimum 75 millimeter wide. Length of strips 3000 millimeter.

2.2.13 Ridge and Valley Plates for Roof Decks

Fabricate plates from the specified structural-quality steel sheets, not less than nominal 1.0 millimeter thick before galvanizing. Provide plates of minimum 120 millimeter wide and bent to provide tight fitting closures at ridges and valleys. Provide a minimum length of ridge and valley plates of 3000 millimeter.

2.2.14 Metal Closure Strips for Roof Decks

Fabricate strips from the specified commercial-quality steel sheets not less than nominal 1.0 millimeter thick before galvanizing. Provide strips from the configuration required to provide tight-fitting closures at open ends and sides of steel roof decking.

2.2.15 Galvanized Steel Angles for Roof Decks

Provide hot-rolled carbon steel angles conforming to JIS G 3106, SM400, 235 MPa, and hot-dip galvanized in accordance with JIS H 8641.

[2.2.16 Sound Absorbing Material

Provide [glass fiber in roll or premolded form for acoustical noncellular steel roof deck] [and] [glass fiber rigid strip for acoustical cellular steel deck] in accordance with the manufacturer's standards. Provide a sample of acoustical material to be used.

]2.2.17 Mechanical Fasteners

Provide mechanical fasteners, such as powder actuated fasteners, pneumatically driven fasteners or self-drilling screws, for anchoring the deck to structural supports and adjoining units[as indicated][that are designed to meet the loads indicated].

]2.2.18 Miscellaneous Accessories

Furnish the manufacturer's standard accessories to complete the deck installation. Furnish metal accessories of the same material as the deck and with the minimum design thickness as follows: saddles, 1.2 mm welding washers, 1.6 mm other metal accessories, 1.0 mm unless otherwise indicated.

PART 3 EXECUTION

3.1 EXAMINATION

Prior to installation of decking units and accessories, examine worksite to verify that as-built structure will permit installation of decking system without modification.

3.2 INSTALLATION

Install steel deck units in accordance with 29 CFR 1926, Subpart R - Steel Erection, ANSI/SDI QA/QC, [ANSI/SDI C][ANSI/SDI NC][ANSI/SDI RD][SDI DDM04] and approved shop drawings. Place units on structural supports, properly adjusted, leveled, and aligned at right angles to supports before

permanently securing in place. Damaged deck and accessories including material which is permanently stained or contaminated, deformed, or with burned holes shall not be installed. Extend deck units over three or more supports unless absolutely impractical. Report inaccuracies in alignment or leveling to the Contracting Officer and make necessary corrections before permanently anchoring deck units. Locate deck ends over supports only. [Lap 50 mm] [Butted] deck ends. Do not use unanchored deck units as a work or storage platform. [Do not fill unanchored deck with concrete.] Permanently anchor units placed by the end of each working day. Do not support suspended ceilings, light fixtures, ducts, utilities, or other loads by steel deck unless indicated. Distribute loads by appropriate means to prevent damage.[Prepare shoring in position before concrete placement begins in composite or form deck.][Size cellular decking provided as electrical raceways to accommodate indicated wiring systems. Chip off burrs and eliminate sharp edges which may damage wiring. Mesh decking panels accurately and place in accordance with UL 209.][Neatly fit acoustical material into the rib voids.]

3.2.1 Attachment

Immediately after placement and alignment, and after correcting inaccuracies, permanently fasten steel deck units to structural supports and to adjacent deck units by welding with normal 16 mm diameter arc spot welds,[fastened with screws, or pneumatically driven fasteners] as indicated on the design drawings and in accordance with manufacturer's recommended procedure[and ANSI/SDI C, ANSI/SDI NC or ANSI/SDI RD]. Clamp or weight deck units to provide firm contact between deck units and structural supports while performing welding [or fastening].[Anchoring the deck to structural supports with powder-actuated fasteners or pneumatically driven fasteners is prohibited.] Attachment of adjacent deck units by button-punching is prohibited.

3.2.1.1 Welding

Perform welding in accordance with JASS 6 using methods and electrodes recommended by the manufacturers of the base metal alloys being used. Ensure only operators previously qualified by tests prescribed in JASS 6 and JIS Z 3801 make welds. Immediately recertify, or replace qualified welders, that are producing unsatisfactory welding. [Indicate] [Conform to the recommendations of the Steel Deck Institute and the steel deck manufacturer]for location, size, and spacing of fastening. [Do][Do not] use welding washers at the connections of the deck to supports. Do not use welding washers at sidelaps. Holes and similar defects will not be acceptable. Attach all partial or segments of deck units to structural supports in accordance with Section 2.5 of SDI DDM04. [Attach shear connectors as shown and welded as per JASS 6 [through the steel deck to the steel member] [directly to the steel member]]. Immediately clean welds by chipping and wire brushing. Heavily coat welds, cut edges and damaged portions of [coated finish with zinc-dust paint conforming to JASS 6] [shop [primed] [painted] finish with the manufacturer's standard touch-up paint].

3.2.1.2 Sidelap Fastening

Lock sidelaps between adjacent floor deck units together by welding or screws as indicated.

3.2.2 Openings

Cut or drill all holes and openings required and be coordinated with the drawings, specifications, and other trades. Frame and reinforce openings through the deck in conformance with SDI DDP. Reinforce [holes and openings 150 to 300 mm across by 1.2 mm thick steel sheet at least 300 mm wider and longer than the opening and be fastened to the steel deck at each corner of the sheet and at a maximum of 150 mm on center. Reinforce holes and openings larger than 300 mm by steel channels or angles installed perpendicular to the steel joists and supported by the adjacent steel joists. Install steel channels or angles perpendicular to the deck ribs and fasten to the channels or angles perpendicular to the steel joists.] [Deck manufacturer shall approve holes or openings larger than 150 mm in diameter prior to drilling or cutting.] [Openings must not interfere with seismic members such as chords and drag struts.]

3.2.3 Deck Damage

SDI MOC3, for repair of deck damage.

3.2.4 Touch-Up Paint

3.2.4.1 Roof Deck

After roof decking installation, wire brush, clean, and touchup paint the scarred areas on top and bottom surfaces of metal roof decking. The scarred areas include welds, weld scars, bruises, and rust spots. Touchup galvanized surfaces with galvanizing repair paint. Touchup painted surfaces with repair paint of painted surfaces.

3.2.4.2 Floor Deck

For floor decking installation, wire brush, clean, and touchup paint the scarred areas on the top and bottom surfaces of the metal floor decking and on the surface of supporting steel members. Include welds, weld scars, bruises, and rust spots for scarred areas. Touched up the galvanized surfaces with galvanizing repair paint. Touch up the painted surfaces with paint for the repair of painted surfaces.

3.2.5 Accessory Installation

3.2.5.1 Adjusting Plates

Provide in locations too narrow to accommodate full-size deck units and install as shown on shop drawings.

3.2.5.2 End Closures

Provide end closure to close open ends of cells at columns, walls, and openings in deck.

3.2.5.3 Closures Above Partitions

Provide for closing voids between cells over partitions that are perpendicular to direction of cells. Provide a one-piece closure strip for partitions 100 mm nominal or less in thickness and two-piece closure strips for wider partitions. [Provide sheet metal closures above fire-rated partitions at both sides of partition with space between filled with fiberglass insulation.] [Provide flexible rubber closures above

acoustic-rated partitions at both sides of partition with space between filled with blanket insulation.]

3.2.5.4 Cover Plates

[Provide metal cover plates, or joint tape, at joints between cellular decking sheets to be used as electrical raceways.] [Where concrete leakage would be a problem, provide metal cover plates, or joint tape, at joints between decking sheets, cellular or noncellular, to be covered with concrete fill.]

[3.2.5.5 Column Closures

Provide for spaces between floor decking and columns which penetrate the deck. Field cut closure plate to fit column in the field and tack weld to decking and columns.

]3.2.5.6 Access Hole Covers

Provide access whole covers to seal holes cut in decking to facilitate welding of the deck to structural supports.

3.2.5.7 Hangers

Provide as indicated to support [utility system] [and] [suspended ceilings]. Space devices [as indicated] [so as to provide one device per 0.60 square meters].

[3.2.6 Sound Absorbing Material

Install sound absorbing [glass fiber roll or premolded form, neatly in voids between perforated webs of acoustical noncellular steel deck] [and] [glass fiber rigid strip, in cells of acoustical cellular steel deck]. Keep sound absorbing material dry before, during and after installation.

]3.2.7 Concrete Work

Prior to placement of concrete, inspect installed decking to ensure that there has been no permanent deflection or other damage to decking. Replace decking which has been damaged or permanently deflected as approved by the Contracting Officer. Place concrete on metal deck in accordance with Construction Practice of ANSI/SDI C or ANSI/SDI NC.

]3.2.8 Preparation of Fire-Proofed Surfaces

Provide deck surfaces, both composite and noncomposite, which are to receive sprayed-on fireproofing, galvanized and free of all grease, mill oil, paraffin, dirt, salt, and other contaminants which impair adhesion of the fireproofing. Complete any required cleaning prior to steel deck installation using a cleaning method that is compatible with the sprayed-on fireproofing.

3.3 ROOF SUMP PANS

Place sump pans over openings in roof decking and fusion welded to top surface of roof decking. Do not exceed spacing of welds of 300 millimeter with not less than one weld at each corner. Field cut opening in the bottom of each roof sump pan to receive the roof drain as part of the work of this section.

3.4 CANT STRIPS FOR ROOF DECKS

Provide strips to be fusion welded to surface of roof decking, secured to wood nailers by galvanized screws or to steel framing by galvanized self-tapping screws or welds. Do not exceed spacing of welds and fasteners of 300 millimeter. Lap end joints a minimum 75 millimeter and secure with galvanized sheet metal screws spaced a maximum 100 millimeter on center.

3.5 RIDGE AND VALLEY PLATES FOR ROOF DECKS

Provide plates to be fusion welded to top surface of roof decking. Lap end joints a minimum 75 millimeter. For valley plates, provide endlaps to be in the direction of water flow.

3.6 CLOSURE STRIPS FOR ROOF DECKS

Provide closure strips at open, uncovered ends and edges of the roof decking and in voids between roof decking and top of walls and partitions where indicated. Install closure strips in position in a manner to provide a weathertight installation.

3.7 ROOF INSULATION SUPPORT FOR ROOF DECKS

Provide metal closure strips for support of roof insulation where rib openings in top surface of metal roof decking occur adjacent to edges and openings. Weld metal closure strips in position.

3.8 CLEANING AND PROTECTION FOR ROOF DECKS

Upon completion of the deck, sweep surfaces clean and prepare for installation of the roofing.

3.9 FIELD QUALITY CONTROL

3.9.1 Headed Stud Inspection

In addition to visual inspection, test and inspect shop-welded shear connectors according to requirements in JASS 6 for stud welding and as follows:

- a. Perform bend tests if visual inspections reveal either a less-than-continuous 360-degree flash or welding repairs to any shear connector.
- b. Conduct tests according to requirements in JASS 6 on additional shear connectors if weld fracture occurs on shear connectors already tested.

3.9.2 Deck Weld Inspection

Visual inspect welds in accordance with JASS 6.

[3.9.3 Decks Not Receiving Concrete

Inspect the decking top surface for distortion after installation. For roof decks not receiving concrete, verify distortion by placing a straight edge across three adjacent top flanges. The maximum allowable gap between the straight edge and the top flanges should not exceed manufacturing and

construction tolerances of supporting members. When gap is more than the allowable, provide corrective measures or replacement. Reinspect decking after performing corrective measures or replacement.

] -- End of Section --